


CUSTOMER APPROVAL  
 APPROVED BY: \_\_\_\_\_  
 DATE: \_\_\_\_\_

**NOTES:**

1. LOGO TO BE SPECIFIED: \_\_\_\_\_.
2. FURNISHED W/(2) 1/2-6 X 4 [102] LONG S.S. HEX HEAD AUGER BOLTS & (2) ø1/2 [13] S.S. FLAT WASHERS.
3. THIS COVER IS RATED FOR A STATIC DESIGN LOAD OF 15,000 LBS. [66,720 N] OVER A 10 [254] X 10 [254] AREA AND MUST PASS A MIN. STATIC TEST LOAD OF 22,500 LBS. [100,085 N].



|   |         |                        |       |                |
|---|---------|------------------------|-------|----------------|
| DIMENSIONS ARE IN INCHES OR MILLIMETERS IN BRACKETS UNLESS OTHERWISE NOTED. |         | WEIGHT                 |       | LOU            |
| BY  | DATE    | 474#                   | 215kg | IC             |
| 09/97   | 1/28/96 | Hubbell                |       | S              |
| CHKD  | DATE    | DRAWN & DESCRIBED      |       | REV            |
| 08/97   | 1/28/96 | QUAZITE® 36 X 72 COVER |       | D              |
| APP'D   | DATE    | STANDARD VERSION       |       | 3/12           |
| M/89  | 1/28/96 | B                      |       |                |
| EST. OR PROJECT NUMBER  |         | SHEET 1 OF 1           |       | DRAWING NUMBER |
| 96049   |         |                        |       | PG3672HA00     |